PROVIDING MORE EPCOR

Gold Bar Wastewater Treatment Plant
Plant Performance Report
February 2021

Digested Sludge: Total Monthly Volume (ML)	62.2

Volume of Flow (ML)

DATE	Peak Flow (ML/D)	Influent INFs	Influent RAW	Effluent Non UV Disinfected OUTFALL 30	Effluent Non UV Disinfected OUTFALL 20	Effluent Non UV Disinfected MPW	Effluent UV Disinfected EPEPS	Effluent UV Disinfected OUTFALL 10 FEC	Effluent UV Disinfected OUTFALL 10 FE
Mon-01	331.1	0.0	246.0	0.0	0.0	11.7	0.0	234.3	234.3
Tue-02	319.8	0.0	238.3	0.0	0.0	11.9	0.0	226.4	226.4
Wed-03	321.8	0.0	238.9	0.0	0.0	12.1	0.0	226.8	226.8
Thu-04	311.6	0.0	236.8	0.0	0.0	12.2	0.0	224.6	224.6
Fri-05	304.0	0.0	236.7	0.0	0.0	12.6	0.0	224.1	224.1
Sat-06	321.4	0.0	236.5	0.0	0.0	12.6	0.0	223.9	223.9
Sun-07	331.0	0.0	242.1	0.0	0.0	12.3	0.0	229.8	229.8
Mon-08	317.2	0.0	242.0	0.0	0.0	12.2	0.0	229.8	229.8
Tue-09	326.1	0.0	244.9	0.0	0.0	12.1	0.0	232.8	232.8
Wed-10	331.6	0.0	239.1	0.0	0.0	11.9	0.0	227.2	227.2
Thu-11	314.0	0.0	247.5	0.0	0.0	11.5	0.0	236.0	236.0
Fri-12	306.7	0.0	244.9	0.0	0.0	11.1	0.0	233.8	233.8
Sat-13	329.6	0.0	241.1	0.0	0.0	10.7	0.0	230.4	230.4
Sun-14	326.8	0.0	240.8	0.0	0.0	10.5	0.0	230.3	230.3
Mon-15	342.3	0.0	244.6	0.0	0.0	10.6	0.0	234.0	234.0
Tue-16	321.7	0.0	249.8	0.0	0.0	10.7	0.0	239.1	239.1
Wed-17	331.4	0.0	248.3	0.0	0.0	10.9	0.0	237.4	237.4
Thu-18	344.7	0.0	247.3	0.0	0.0	11.0	0.0	236.3	236.3
Fri-19	326.9	0.0	252.4	0.0	0.0	10.8	0.0	241.6	241.6
Sat-20	351.4	0.0	251.6	0.0	0.0	10.6	0.0	241.0	241.0
Sun-21	403.5	0.0	261.8	0.0	0.0	10.5	0.0	251.3	251.3
Mon-22	495.1	0.0	295.8	21.2	0.0	9.9	0.0	264.7	264.7
Tue-23	343.4	0.0	258.5	0.0	0.0	10.8	0.0	247.7	247.7
Wed-24	348.9	0.0	255.3	0.0	0.0	10.9	0.0	244.4	244.4
Thu-25	415.9	0.0	261.0	0.0	0.0	11.1	0.0	249.9	249.9
Fri-26	333.2	0.0	251.7	0.0	0.0	11.1	0.0	240.6	240.6
Sat-27	333.5	0.0	244.8	0.0	0.0	10.7	0.0	234.1	234.1
Sun-28	348.1	0.0	247.7	0.0	0.0	11.0	0.0	236.7	236.7
Average	340.5	0.0	248.1	0.8	0.0	11.3	0.0	236.0	236.0
Minimum	304.0	0.0	236.5	0.0	0.0	9.9	0.0	223.9	223.9
Maximum	495.1	0.0	295.8	21.2	0.0	12.6	0.0	264.7	264.7
GeoMean	---	---	---	---	---	---	---	---	---
TOTAL	---	0	6,946	21	0	316	0	6,609	6,609

Liquid Stream Quality

DATE	pH@25°C RAW	pH@25°C OUTFALL 30	pH@25°C OUTFALL 20	pH@25°C OUTFALL 10 FEC	TSS (mg/L) RAW	TSS OUTFALL 30	TSS OUTFALL 20	TSS EPEPS	TSS OUTFALL 10 FEC	TSS OUTFALL 10 FE
Mon-01	7.5			7.5	292				4.3	4.3
Tue-02	7.5			7.5	328				3.3	3.3
Wed-03	7.4			7.6	304				3.1	3.1
Thu-04	7.6			7.7	292				3.7	3.7
Fri-05	7.5			7.7	316				2.8	2.8
Sat-06	7.7			7.5	300				3.2	3.2
Sun-07	7.5			7.5	288				3.1	3.1
Mon-08	7.5			7.5	266				4.8	4.8
Tue-09	7.5			7.6	308				5.2	5.2
Wed-10	7.4			7.5	344				5.1	5.1
Thu-11	7.6			7.9	312				6.0	6.0
Fri-12	7.4			7.6	344				3.5	3.5
Sat-13	7.4			7.6	340				3.0	3.0
Sun-14	7.5			7.6	308				2.6	2.6
Mon-15	7.5			7.6	264				3.3	3.3
Tue-16	7.4			7.6	304				4.2	4.2
Wed-17	7.5			7.5	304				3.0	3.0
Thu-18	7.5			7.6	316				2.8	2.8
Fri-19	7.5			7.6	332				2.9	2.9
Sat-20	7.5			7.6	452				3.9	3.9
Sun-21	7.4			7.6	316	162			9.0	9.0
Mon-22	7.4	7.4		7.6	364	436			5.6	5.6
Tue-23	7.4			7.5	316				3.2	3.2
Wed-24	7.5			7.6	352				6.0	6.0
Thu-25	7.5			7.5	464				27.2	27.2
Fri-26	7.5			7.7	324				9.7	9.7
Sat-27	7.6			7.6	272				3.4	3.4
Sun-28	7.4			7.6	332				3.1	3.1
Average	7.5	7.4	---	7.6	323	299	---	---	5.0	5.0
Minimum	7.4	7.4	---	7.5	264	162	---	---	2.6	2.6
Maximum	7.7	7.4	---	7.9	464	436	---	---	27.2	27.2
GeoMean	---	---	---	---	---	---	---	---	---	---
TOTAL	---	---	---	---	---	---	---	---	---	---

DATE	BOD_5<BOD_5 (mg/L) RAW BOD_5	OUTFALL 30 BOD_5	OUTFALL 20 BOD_5	EPEPS BOD_5	OUTFALL 10 FEC <BOD_5	OUTFALL 10 FE <BOD_5	TP (mg/L) RAW	TP OUTFALL 30	TP OUTFALL 20	TP EPEPS	TP OUTFALL 10 FEC	TP OUTFALL 10 FE
Mon-01	340				2.0	2.0	8.32				0.28	0.28
Tue-02	291				3.0	3.0	8.14				0.28	0.28
Wed-03	294				< 2.0	2.0	7.31				0.24	0.24
Thu-04	332				3.0	3.0	7.00				0.23	0.23
Fri-05	324				2.0	2.0	7.63				0.24	0.24
Sat-06	442				2.0	2.0	7.92				0.23	0.23
Sun-07	332				2.0	2.0	7.60				0.23	0.23
Mon-08	311				2.0	2.0	6.54				0.27	0.27
Tue-09	285				2.0	2.0	7.21				0.24	0.24
Wed-10	291				3.0	3.0	7.05				0.27	0.27
Thu-11	334				3.0	3.0	6.97				0.30	0.30
Fri-12	329				< 2.0	2.0	6.77				0.27	0.27
Sat-13	342				2.0	2.0	6.76				0.21	0.21
Sun-14	310				2.0	2.0	7.15				0.22	0.22
Mon-15	332				2.0	2.0	6.87				0.23	0.23
Tue-16	350				3.0	3.0	6.91				0.21	0.21
Wed-17	305				2.0	2.0	7.34				0.20	0.20
Thu-18	325				3.0	3.0	7.22				0.19	0.19
Fri-19	353				2.0	2.0	6.97				0.20	0.20
Sat-20	365				2.0	2.0	6.68				0.36	0.36
Sun-21	269				13.0	13.0	6.62				0.58	0.58
Mon-22	286	180			3.0	3.0	6.08	5.26			0.37	0.37
Tue-23	372				3.0	3.0	6.9				0.19	0.19
Wed-24	281				3.0	3.0	6.14				0.29	0.29
Thu-25	262				10.0	10.0	6.46				1.18	1.18
Fri-26	337				4.0	4.0	7.49				0.50	0.50
Sat-27	295				2.0	2.0	7.24				0.20	0.20
Sun-28	262				2.0	2.0	6.77				0.19	0.19
Average	320	180	---	---	3.1	3.1	7.07	5.26	---	---	0.30	0.30
Minimum	262	180	---	---	< 2.0	2.0	6.08	5.26	---	---	0.19	0.19
Maximum	442	180	---	---	13.0	13.0	8.3	5.26	---	---	1.18	1.18
GeoMean	---	---	---	---	---	---	---	---	---	---	---	---
TOTAL	---	---	---	---	---	---	---	---	---	---	---	---

DATE	NH3-N (mg/L) RAW	NH3 OUTFALL 30	NH3 OUTFALL 20	NH3 EPEPS	NH3 OUTFALL 10 FEC	NH3 OUTFALL 10 FE	TKN (mg/L) RAW	TKN OUTFALL 30	TKN OUTFALL 20	TKN OUTFALL 10 FEC	NO_2+NO_3 (mg/L) RAW	NO_2+NO_3 OUTFALL 30	NO_2+NO_3 OUTFALL 20	NO_2+NO_3 OUTFALL 10 FEC	Chloride (mg/L) RAW	Chloride OUTFALL 30	Chloride OUTFALL 20	Chloride OUTFALL 10 FEC	*E. coli* (Counts/100 mL) RAW X10^6	*E. coli* OUTFALL 30 X10^6	*E. coli* OUTFALL 20 X10^6	*E. coli* OUTFALL 10 FEC
Mon-01	34.6				1.96	1.96	64.7			3.90				8.23	108			99				3
Tue-02	38.4				1.45	1.45	65.9			3.50				8.54	110			107				6
Wed-03	37.2				0.93	0.93	58.2			2.40	0.09			7.6	108			109				2
Thu-04	37.6				1.16	1.16	56.8			2.70				7.0	115			109				< 1
Fri-05	34.0				1.15	1.15	63.9			3.00				7.0	100			110				4
Sat-06	37.2				1.78	1.78	66.9			3.40				5.7	89			106				2
Sun-07	37.3				2.50	2.50	65.3			4.50				6.28	87			90				4
Mon-08	36.9				2.28	2.28	55.5			4.20				5.81	83			80				5
Tue-09	36.6				2.13	2.13	59.1			4.10				5.5	85			85				8
Wed-10	39.9				2.52	2.52	58.4			4.30	0.07			5.30	87			86				4
Thu-11	35.0				2.78	2.78	56.7			4.60				5.2	84			90				4
Fri-12	23.2				2.79	2.79	57.1			4.70				5.1	85			87				690
Sat-13	35.9				2.63	2.63	58.1			4.40				5.3	85			86				4
Sun-14	34.5				2.94	2.94	59.2			4.90				5.53	74			79				4
Mon-15	37.8				3.17	3.17	60.7			5.00				5.89	85			79				7
Tue-16	36.0				3.13	3.13	58.5			5.40				6.22	85			80				4
Wed-17	35.6				2.77	2.77	53.4			4.70	0.11			5.9	92			89				3
Thu-18	35.5				2.82	2.82	58.6			4.90				6.1	98			94				1
Fri-19	35.7				2.62	2.62	53.8			4.30				5.4	110			99				1
Sat-20	34.9				2.70	2.70	45.3			4.20				4.9	143			86				4
Sun-21	31.1	3.0			3.01	3.01	54.6			6.00				5.4	212			145				5
Mon-22	29.6	32.5			5.11	5.11	50.1	45.3		7.40		0.19		3.8	354	509		227		1.6		4
Tue-23	33.6				3.50	3.50	55.0			5.00				4.0	152			276	1.2			6
Wed-24	33.5				2.89	2.89	49.3			4.60	0.01			4.4	132			171				6
Thu-25	30.7				2.75	2.75	47.9			7.80				4.6	170			147	2.0			12
Fri-26	33.9				3.44	3.44	57.0			6.00				4.4	114			157				6
Sat-27	31.2				3.23	3.23	56.6			6.10				4.5	99			122				6
Sun-28	33.6				3.20	3.20	54.8			6.00				5.6	132			106				3
Average	34.7	17.7	---	---	2.62	2.62	57.2	45.3	---	4.71	0.07	0.19	---	5.7	117	509	---	114	---	---	---	---
Minimum	23.2	3.0	---	---	0.93	0.93	45.3	45.3	---	2.40	0.01	0.19	---	3.84	74	509	---	79	1.2	1.6	---	< 1
Maximum	39.9	32.5	---	---	5.11	5.11	66.9	45.3	---	7.80	0.11	0.19	---	8.5	354	509	---	276	2.0	1.6	---	690
GeoMean	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	1.5	1.6	---	5
TOTAL	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

* Contact Laboratory for information about the quality assurance associated with the results

Enhanced Primary Treatment (EPT) Usage					
Total Bypass (hr)	EPT Usage (hr)	% Usage	Total Bypass YTD (hr)	EPT Usage YTD (hr)	% Usage YTD
8	8	100%	8	8	100%

Report Comments

AEP Ref #

RAW	Untreated Influent into the plant
INF	Untreated wastewater from collection system
INFs	Influent, screened at the Headworks Diversion Structure
PE	Primary Effluent from conventional primaries
PE 30	Primary Effluent from conventional primaries discharged via Outfall 30
EPT	Enhanced Primary Treatment
EPE	Enhanced Primary Effluent
EPEPS	Enhanced Primary Effluent Pump Station
FE	Final Effluent from secondary treatment process (with biological nutrient removal). Pre-Ultraviolet disinfection.

FEC	Combined post-UV disinfection (FE+EPEPS)
OUTFALL 10	UV-disinfected, discharged via OUTFALL 10
OUTFALL 20	Combined Bypass (RAW + PE + EPE)
OUTFALL 30	Combined Bypass (INF + INFS + PE30 + EPE)
MPW	Membrane Product Water (Effluent re-use water)
ML	Megalitre (1,000,000 Litre)
MPN	Most Probable Number
NR	No Result
NS	No Sample
INS	Insufficient Sample
``SP	Alberta Environment & Parks

Alfredo Suarez M.Sc.; P.Eng.
Senior Manager, Operations

Daniel Calcines B.Sc., P. Chem
Manager, Laboratory Customer Relations