PROVIDING MORE EPCOR

Gold Bar Wastewater Treatment Plant
Plant Performance Report
November 2023

Digested Sludge: Total Monthly Volume (ML)	70.3

Volume of Flow (ML)

DATE	Peak Flow (MLD)	Influent INFs	Influent RAW	Effluent Non UV Disinfected OUTFALL 30	Effluent Non UV Disinfected OUTFALL 20	Effluent Non UV Disinfected MPW	Effluent UV Disinfected EPEPS	Effluent UV Disinfected OUTFALL 10 FEC	Effluent UV Disinfected OUTFALL 10 FE
Wed-01	372.0	0.0	267.5	0.0	0.0	11.5	0.0	256.0	256.0
Thu-02	333.5	0.0	274.5	0.0	0.0	12.2	0.0	262.3	262.3
Fri-03	320.5	0.0	272.7	0.0	0.0	11.6	0.0	261.1	261.1
Sat-04	369.9	0.0	268.3	0.0	0.0	11.1	0.0	257.2	257.2
Sun-05	417.4	0.0	282.5	0.0	0.0	11.6	0.0	270.9	270.9
Mon-06	336.9	0.0	276.4	0.0	0.0	11.6	0.0	264.8	264.8
Tue-07	321.8	0.0	267.3	0.0	0.0	10.0	0.0	257.3	257.3
Wed-08	320.9	0.0	267.8	0.0	0.0	10.9	0.0	256.9	256.9
Thu-09	344.6	0.0	268.3	0.0	0.0	10.9	0.0	257.4	257.4
Fri-10	336.9	0.0	270.6	0.0	0.0	11.1	0.0	259.5	259.5
Sat-11	342.1	0.0	264.3	0.0	0.0	11.2	0.0	253.1	253.1
Sun-12	342.2	0.0	262.0	0.0	0.0	11.0	0.0	251.0	251.0
Mon-13	342.4	0.0	266.5	0.0	0.0	11.6	0.0	254.9	254.9
Tue-14	354.1	0.0	270.0	0.0	0.0	10.7	0.0	259.3	259.3
Wed-15	400.3	0.0	269.4	0.0	0.0	11.0	0.0	258.4	258.4
Thu-16	405.5	0.0	266.8	0.0	0.0	11.0	0.0	255.8	255.8
Fri-17	396.9	0.0	268.0	0.0	0.0	10.9	0.0	257.1	257.1
Sat-18	333.6	0.0	265.6	0.0	0.0	10.7	0.0	254.9	254.9
Sun-19	356.4	0.0	268.6	0.0	0.0	10.9	0.0	257.7	257.7
Mon-20	340.0	0.0	271.0	0.0	0.0	10.9	0.0	260.1	260.1
Tue-21	331.7	0.0	264.3	0.0	0.0	11.2	0.0	253.1	253.1
Wed-22	336.8	0.0	263.9	0.0	0.0	11.1	0.0	252.8	252.8
Thu-23	393.2	0.0	264.5	0.0	0.0	11.5	0.0	253.0	253.0
Fri-24	340.2	0.0	268.4	0.0	0.0	10.9	0.0	257.5	257.5
Sat-25	341.8	0.0	264.0	0.0	0.0	11.0	0.0	253.0	253.0
Sun-26	355.7	0.0	265.9	0.0	0.0	11.3	0.0	254.6	254.6
Mon-27	331.9	0.0	271.1	0.0	0.0	11.0	0.0	260.1	260.1
Tue-28	325.0	0.0	265.0	0.0	0.0	10.9	0.0	254.1	254.1
Wed-29	346.5	0.0	266.5	0.0	0.0	10.8	0.0	255.7	255.7
Thu-30	342.5	0.0	267.6	0.0	0.0	10.7	0.0	256.9	256.9
Average	351.1	0.0	268.3	0.0	0.0	11.1	0.0	257.2	257.2
Minimum	320.5	0.0	262.0	0.0	0.0	10.0	0.0	251.0	251.0
Maximum	417.4	0.0	282.5	0.0	0.0	12.2	0.0	270.9	270.9
GeoMean	---	---	---	---	---	---	---	---	---
TOTAL	---	0	8,049	0	0	333	0	7,717	7,717

Liquid Stream Quality

DATE	pH@25°C RAW	pH@25°C OUTFALL 30	pH@25°C OUTFALL 20	pH@25°C OUTFALL 10 FEC	TSS (mg/L) RAW	TSS OUTFALL 30	TSS OUTFALL 20	TSS EPEPS	TSS OUTFALL 10 FEC	TSS OUTFALL 10 FE
Wed-01	7.5			7.5	332				3.1	3.1
Thu-02	7.5			7.3	288				3.7	3.7
Fri-03	7.5			7.5	320				3.9	3.9
Sat-04	7.5			7.5	297				3.8	3.8
Sun-05	7.5			7.5	316				3.6	3.6
Mon-06	7.3			7.4	313				3.2	3.2
Tue-07	7.4			7.4	368				4.7	4.7
Wed-08	7.3			7.2	303				3.7	3.7
Thu-09	7.5			7.4	300				3.3	3.3
Fri-10	7.5			7.4	307				3.8	3.8
Sat-11	7.5			7.4	308				2.5	2.5
Sun-12	7.3			7.3	307				2.6	2.6
Mon-13	7.3			7.3	312				3.6	3.6
Tue-14	7.4			7.3	324				3.6	3.6
Wed-15	7.3			7.3	323				4.9	4.9
Thu-16	7.3			7.3	304				3.4	3.4
Fri-17	7.4			7.4	304				3.4	3.4
Sat-18	7.5			7.5	296				3.6	3.6
Sun-19	7.6			7.5	310				3.3	3.3
Mon-20	7.5			7.5	284				3.9	3.9
Tue-21	7.5			7.5	604				3.2	3.2
Wed-22	7.5			7.6	308				2.7	2.7
Thu-23	7.4			7.6	308				3.4	3.4
Fri-24	7.6			7.5	312				3.0	3.0
Sat-25	7.6			7.5	284				3.1	3.1
Sun-26	7.6			7.6	277				3.2	3.2
Mon-27	7.5			7.6	309				3.1	3.1
Tue-28	7.5			7.6	360				3.5	3.5
Wed-29	7.4			7.6	356				4.5	4.5
Thu-30	7.6			7.7	332				3.2	3.2
Average	7.5	---	---	7.4	322	---	---	---	3.5	3.5
Minimum	7.3	---	---	7.2	277	---	---	---	2.5	2.5
Maximum	7.6	---	---	7.7	604	---	---	---	4.9	4.9
GeoMean	---	---	---	---	---	---	---	---	---	---
TOTAL	---	---	---	---	---	---	---	---	---	---

DATE	BOD_5/$cBOD_5$ (mg/L) RAW	BOD_5 OUTFALL 30	BOD_5 OUTFALL 20	BOD_5 EPEPS	BOD_5 OUTFALL 30 FEC	BOD_5 OUTFALL 30 FE	TP (mg/L) RAW	TP OUTFALL 30	TP OUTFALL 20	TP EPEPS	TP OUTFALL 10 FEC	TP OUTFALL 10 FE
Wed-01	313				2	2	8.56				0.31	0.31
Thu-02	307				2	2	8.39				0.29	0.29
Fri-03	318				3	3	7.52				0.31	0.31
Sat-04	285				2	2	7.77				0.31	0.31
Sun-05	324				2	2	8.10				0.29	0.29
Mon-06	300				3	3	8.02				0.26	0.26
Tue-07	290				3	3	7.54				0.28	0.28
Wed-08	301				3	3	8.72				0.30	0.30
Thu-09	245				2	2	8.77				0.30	0.30
Fri-10	268				2	2	8.96				0.29	0.29
Sat-11	288				2	2	3.65				0.29	0.29
Sun-12	260				2	2	8.66				0.26	0.26
Mon-13	312				3	3	9.11				0.25	0.25
Tue-14	300				2	2	8.62				0.28	0.28
Wed-15	290				2	2	8.93				0.28	0.28
Thu-16	286				3	3	8.30				0.28	0.28
Fri-17	297				2	2	8.92				0.26	0.26
Sat-18	316				3	3	9.07				0.28	0.28
Sun-19	288				2	2	8.40				0.29	0.29
Mon-20	293				2	2	8.16				0.28	0.28
Tue-21	191				2	2	9.68				0.25	0.25
Wed-22	324				2	2	8.29				0.28	0.28
Thu-23	324				2	2	8.39				0.24	0.24
Fri-24	357				2	2	8.21				0.23	0.23
Sat-25	232				< 2	2	8.42				0.23	0.23
Sun-26	331				2	2	8.94				0.19	0.19
Mon-27	295				3	3	8.66				0.24	0.24
Tue-28	311				3	3	8.90				0.24	0.24
Wed-29	303				3	3	8.53				0.28	0.28
Thu-30	320				2	2	8.86				0.26	0.26
Average	295	---	---	---	2.3	2.3	8.37	---	---	---	0.27	0.27
Minimum	191	---	---	---	< 2	2	3.65	---	---	---	0.19	0.19
Maximum	357	---	---	---	3	3	9.68	---	---	---	0.31	0.31
GeoMean	---	---	---	---	---	---	---	---	---	---	---	---
TOTAL	---	---	---	---	---	---	---	---	---	---	---	---

DATE	NH_3-N (mg/L) RAW	NH_3-N OUTFALL 30	NH_3-N OUTFALL 20	NH_3-N EPEPS	NH_3-N OUTFALL 10 FEC	NH_3-N OUTFALL 10 FE	un-ionized NH_3-N (mg/L) OUTFALL 30	un-ionized NH_3-N OUTFALL 20	un-ionized NH_3-N OUTFALL 10	TKN (mg/L) RAW	TKN OUTFALL 30	TKN OUTFALL 20	TKN OUTFALL 10 FEC	NO_3+NO_2 (mg/L) RAW	NO_3+NO_2 OUTFALL 30	NO_3+NO_2 OUTFALL 20	NO_3+NO_2 OUTFALL 10 FEC	Chloride (mg/L) RAW	Chloride OUTFALL 30	Chloride OUTFALL 20	Chloride OUTFALL 10 FEC	E. coli (Counts/100 mL) RAW	E. coli OUTFALL 30	E. coli OUTFALL 20	E. coli OUTFALL 10
																						X10^6	X10^6	X10^6	FEC
Wed-01	37.2				0.62	0.62				50.0			1.9	< 0.01			11.3	87.9			95.8				10
Thu-02	37.0				0.78	0.78				50.2			2.1				11.4	82.1			93.3				7
Fri-03	30.3				0.56	0.56				43.0			1.7				12.6	79.3			90.7				4
Sat-04	37.5				0.68	0.68				44.2			1.8				9.75	83.4			89.0				6
Sun-05	35.1				1.20	1.20				46.3			2.3				9.95	81.3			82.6				13
Mon-06	34.2				1.11	1.11				45.2			2.2				9.92	86.0			78.8				4
Tue-07	33.9				1.05	1.05				45.4			2.2				9.89	85.8			88.9				5
Wed-08	35.7				1.97	1.97				52.8			3.3	< 0.01			10.4	86.1			88.1	2.8			6
Thu-09	36.2				2.57	2.57				52.0			3.8				10.1	85.8			91.2				8
Fri-10	37.2				1.95	1.95				54.3			3.3				11.4	80.4			88.2				4
Sat-11	36.1				1.63	1.63				38.3			3.2				11.4	80.2			89.8				4
Sun-12	36.7				1.89	1.89				50.8			3.1				11.4	73.9			82.5				2
Mon-13	37.9				1.85	1.85				52.9			3.5				11.4	82.5			80.5				4
Tue-14	31.5				1.92	1.92				57.3			3.4				10.6	88.1			85.1				5
Wed-15	32.3				0.96	0.96				51.2			2.4	< 0.01			9.22	84.2			88.3				5
Thu-16	35.7				1.73	1.73				48.9			2.7				8.62	90.1			87.7				1
Fri-17	36.1				1.09	1.09				48.4			2.3				9.20	83.5			89.5				4
Sat-18	36.9				1.12	1.12				51.6			2.4				9.16	79.9			87.6				5
Sun-19	37.4				2.01	2.01				49.2			2.9				10.3	76.4			83.0				4
Mon-20	35.5				2.14	2.14				49.3			3.5				9.19	87.1			84.8				3
Tue-21	36.6				1.76	1.76				60.1			2.8				7.43	87.4			91.3	6.6			13
Wed-22	35.0				1.23	1.23				47.1			2.3	< 0.01			7.98	84.1			90.0				5
Thu-23	35.5				1.09	1.09				47.6			2.3				8.04	83.9			89.0				5
Fri-24	33.8				1.36	1.36				55.8			3.1				8.51	85.4			87.0				4
Sat-25	35.2				1.43	1.43				56.6			2.9				8.55	76.4			89.5				5
Sun-26	35.8				2.01	2.01				61.1			3.4				8.50	73.3			87.3				10
Mon-27	31.0				1.94	1.94				56.7			3.4				7.52	87.5			79.7				10
Tue-28	34.2				0.58	0.58				55.7			2.0				7.30	81.7			90.5				4
Wed-29	31.9				1.45	1.45				53.0			2.9	< 0.01			6.38	91.8			91.7				10
Thu-30	33.1				1.71	1.71				54.9			3.1				7.23	85.4			91.1				5
Average	35.1	---	---	---	1.45	1.45	---	---	---	51.0	---	---	2.7	0.01	---	---	9.49	83.4	---	---	87.8		---	---	
Minimum	30.3	---	---	---	0.56	0.56	---	---	---	38.3	---	---	1.7	< 0.01	---	---	6.38	73.3	---	---	78.8	2.8	---	---	1
Maximum	37.9	---	---	---	2.57	2.57	---	---	---	61.1	---	---	3.8	0.01	---	---	12.6	91.8	---	---	95.8	6.6	---	---	13
GeoMean	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	4.3	---	---	5.1
TOTAL	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

* Contact Laboratory for information about the quality assurance associated with the results

Enhanced Primary Treatment (EPT) Usage

Total Bypass (hr)	EPT Usage (hr)	% Usage	Total Bypass YTD (hr)	EPT Usage YTD (hr)	% Usage YTD
0	0	100%	486	486	100%

Report Comments

AEP Ref #

RAW	Untreated Influent into the plant
INF	Untreated wastewater from collection system
INFs	Influent, screened at the Headworks Diversion Structure
PE	Primary Effluent from conventional primaries
PE 30	Primary Effluent from conventional primaries discharged via Outfall 30
EPT	Enhanced Primary Treatment
EPE	Enhanced Primary Effluent
EPEPS	Enhanced Primary Effluent Pump Station
FE	Final Effluent from secondary treatment process (with biological nutrient removal). Pre-Ultraviolet disinfection.
FEC	Combined post-UV disinfection (FE+EPEPS)
OUTFALL 10	UV-disinfected, discharged via OUTFALL 10
OUTFALL 20	Combined Bypass (RAW + PE + EPE)
OUTFALL 30	Combined Bypass (INF + INFS + PE30 + EPE)
MPW	Membrane Product Water (Effluent re-use water)
ML	Megalitre (1,000,000 Litre)
MPN	Most Probable Number
NR	No Result
NS	No Sample
INS	Insufficient Sample
AEP	Alberta Environment & Parks

Trina Manning M.Sc., P.Eng.
Senior Manager, WWTP Operations

Jeff Charrois PhD
Senior Manager, Analytical Operations