



LAKE HAVASU/PARKER

2024 WATER QUALITY REPORT

epcor.com

PWS ID AZ0408015 (Lake Havasu), AZ0415006 (Moovalya Keys), AZ0415058 (Holiday Harbor), AZ0415010 (Lakeside),
AZ0415011 (Marina Village), AZ0415027 (Parker Dam), AZ0415040 (Rio Lindo)

Clean Water Promise

At EPCOR, we take water quality seriously – and we're proud to consistently provide clean, fresh, high-quality water to our customers in Arizona and New Mexico. We conduct hundreds of tests daily, and hundreds of thousands of tests annually, across our systems to ensure your water meets or exceeds all state and federal standards.

That's our Clean Water Promise.

EPCOR expertly monitors water supplies, carefully maintaining and treating them before the first drop reaches your tap. In addition to monitoring water supply, we also constantly maintain and improve the miles of pipelines, water mains, wells, treatment plants, and hydrants that make up your water system.

The attached water quality report for your system, which includes data collected up through 2024, demonstrates our care and commitment as your water provider.

We have long been innovative and proactive in terms of how we source water as a precious resource and treat the supply to ensure clean, high-quality water for our communities. We continue to innovate for the future.

You may have heard that last year, the federal government's Environmental Protection Agency set the first federal drinking water limits for PFAS, or perfluoroalkyl and polyfluoroalkyl substances, also known as forever chemicals.

EPCOR is proud of our water and, as we monitor and test to meet new regulations, we continue to pledge that we will keep meeting or exceeding all water quality standards.



Sincerely,

Shawn Bradford

Shawn Bradford
Senior Vice President,
Regulated US Water

QUESTIONS?

EPCOR Customer Care:

1-800-383-0834 ■ mywater@epcor.com

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.



YOU WANT TO KNOW WHAT'S IN THE WATER YOU'RE DRINKING

As your water service provider, we're committed to ensuring the quality and safety of that water. That's why you are receiving this annual water quality report from us. We hope it will help you understand your community's water a little better and what we're doing to protect it.

WHAT WILL I FIND IN THIS REPORT?

This report complies with state and U.S. Environmental Protection Agency (EPA) drinking water regulations.

In it you'll find information on:

- Where your water comes from
- Protecting your water
- What's in your water

Information in this report is compiled, in part, from analytical data generated by laboratories certified in drinking water analysis.

READ THIS REPORT – AND SHARE IT!

Reading this report and understanding your community's water is the first step. But it's also important to share this information with those who might not receive it directly. If you're a landlord, business, school or hospital, please share this report with water users in your community.



About Your Water

LAKE HAVASU/PARKER

ABOUT YOUR DISTRICT

- EPCOR provides water service to approximately 2,300 service connections in the northwestern area of the state, primarily in an unincorporated area of Mohave County to the north of Lake Havasu City.
- EPCOR also provides water to a small group of customers within the city limits.

Parker

- EPCOR provides water service to approximately 2,200 service connections in six stand alone systems in the Town of Parker.

WHERE YOUR WATER COMES FROM

- Lake Havasu – Groundwater pumped from the Lake Havasu Basin
- Parker – Colorado River Water

Additional Information About the Groundwater in the Lake Havasu area

The Lake Havasu Basin covers approximately 275 square miles and is bordered on the west by the Colorado River. The Lake Havasu Basin contains stream and basin-fill alluvium consisting of sand, silt and gravel and is replenished by the Colorado River.

How We Protect Groundwater Together

Both groundwater and the associated pumping and delivery facilities are part of a complex system that needs not just monitoring, but also maintenance. From pipelines to water mains, wells to hydrants, we're ensuring that the groundwater supply is protected and accessible.

How You Can Help

Properly dispose of hazardous household chemicals on hazardous material collection days and limit your pesticide and fertilizer use. For information on household hazardous material collection days in your area, contact the **Arizona Department of Environmental Quality** at **602-771-2300** or **Earth911.com**.

NOTICE OF SOURCE WATER ASSESSMENT

In 2004, the Arizona Department of Environmental Quality (ADEQ) completed a source water assessment for three wells used by EPCOR-Havasú. The assessment reviewed the adjacent land uses that may pose a potential risk to the sources. These risks include, but are not limited to, gas stations, landfills, dry cleaners, agriculture fields, wastewater treatment plants and mining activities. Once ADEQ identified the adjacent land uses, they were ranked as to their potential to affect the water sources. The results of the assessment found that there were no adjacent land uses that pose a risk to the sources.

In 2003, ADEQ completed source water assessments of the surface water source used to serve the Marina Village, Parker Dam, Rio Lindo, and Holiday Harbor public water systems (PWS). Based on the information available at the time on the hydrogeologic settings and adjacent land uses that are in the specified proximity of the drinking water sources of these systems, ADEQ gave a high risk designation for the degree to which these systems drinking water sources are protected. A designation of high risk indicates there may be additional source water protection measures which can be implemented on the local level. This does not imply that the source water is contaminated nor does it mean that contamination is imminent. Rather, it simply states that land use activities or hydrogeologic conditions exist that make the source water susceptible to possible future contamination. The ADEQ did not assess the Moovalya Keys or Lakeside systems in 2003 either because the PWS was either inactive at the time or the PWS did not exist

The complete assessments are available for inspection at the Arizona Department of Environmental Quality, 1110 W. Washington, Phoenix, AZ 85007, between the hours of 8 a.m. and 5 p.m. For more information please contact **ADEQ** at **602-771-2300**.

GETTING INVOLVED

Consulting with the community is important to us. If you have a question, concern or suggestion about your local water system, please contact our Customer Care team at **1-800-383-0834**.

What You Can Expect to Find in Your Water

SOURCES OF DRINKING WATER

The sources of drinking water—both tap water and bottled water—include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over land surfaces or through the ground, it can acquire naturally occurring minerals. In some cases it can also acquire radioactive material and substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Information Hotline** at **1-800-426-4791**.

DID YOU KNOW?

Tap water costs a lot less than what you pay for other beverages. **A gallon of water costs you about 1 penny.** Compare that to the cost of a gallon of these beverages*:

- Milk = \$4.05/gallon
- Orange Juice = \$5.00/gallon
- Beer = \$15.00/gallon
- Bottled Water = \$1.27/gallon
- Wine = \$14.38/gallon

* Costs for milk, orange juice and bottled water obtained from Bureau of Labor Statistics and Beverage Marketing Association reports. Other costs determined by calculating average supermarket pricing for bottles of soda, wine and beer and converting to a gallon.

SUBSTANCES THAT MAY BE PRESENT IN SOURCE WATER

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations or wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and Herbicides, may come from a variety of sources, such as agriculture, urban stormwater runoff and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban stormwater runoff and septic systems.

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.



Since 2012, EPCOR has been recognized with over 300 awards for safety and operational excellence in delivering your water every day.



ENSURING YOUR WATER IS SAFE

To ensure that tap water is safe to drink, the EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems.

To ensure bottled water is safe to drink, U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water.

What You Can Expect to Find in Your Water

SPECIAL HEALTH INFORMATION

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants may be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the **EPA's Safe Drinking Water Information Hotline at 1-800-426-4791**.

Lead

EPCOR monitored the water at 20 Lake Havasu residences in 2022 and 55 Parker system residences for lead and copper in 2023. All results met the federal lead and copper standards. The 75 houses sampled were representative of the types of houses throughout the system. If your house was sampled you would have received the analytical results. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. EPCOR is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the **Safe Drinking Water Information Hotline** or at www.epa.gov/safewater/lead.

Did You Know?

There are thousands of known per- and polyfluoroalkyl substances (PFAS) found in daily life including food-handling materials, non-stick cookware, medical devices, personal care products, and even construction equipment. Because PFAS is found in so many everyday products, measuring the harmfulness of these chemicals is difficult and not yet fully understood. As the Environmental Protection Agency (EPA), Centers for Disease Control and Prevention (CDC) and other federal regulators continue to research these chemicals and determine a national standard for the safe level of exposure to these chemicals, EPCOR continues its role in testing for PFAS and finding ways to mitigate PFAS levels when found in drinking water sources. In 2024, EPA finalized six new PFAS drinking water standards and water systems must be in compliance with the new standards no later than 2029. EPCOR is already taking action by beginning engineering and design work to bring all our locations into compliance ahead of the 2029 deadline.

HOME WATER TREATMENT UNITS

Failure to perform maintenance on your home water treatment unit can result in poor water quality. If you installed a home water treatment system such as a water softener or reverse osmosis system, please remember to follow the manufacturer's instructions on operation and maintenance. For more information, contact the manufacturer of your treatment system for maintenance instructions or assistance. Additional information about home water treatment systems is available from the **Water Quality Association** at **630-505-0160** or by visiting wqa.org.

Frequently Asked Questions

WHAT IS THE WHITE OR COLORED DEPOSIT ON MY DISHES OR FAUCETS?

In most cases, the deposits or sediments left behind after water evaporates are calcium carbonate. The amount of calcium in the water is referred to as hardness. Cleaning with white vinegar can help to dissolve and remove deposits. Using a commercial conditioner, liquid detergents or the “air-dry” option in dishwashers can help to decrease the calcium carbonate found on dishes.

ARE THE DEPOSITS OR HARD WATER HARMFUL?

Hardness and/or the deposits left by hard water don’t pose a health concern and may have health benefits. We don’t treat drinking water for water hardness that can result in hard water deposits.

WHAT IS THE LEVEL OF HARDNESS IN MY WATER?

6 - 8 grains per gallon (gpg) for the Lake Havasu system and 16 to 18 gpg for the Parker systems.

Degree of water hardness range (gpg)

Soft	Less than 1
Slightly Hard	1 to 3.4
Moderately Hard	3.5 to 6.9
Hard	7 to 10.4
Very Hard	Greater than 10.5

WHY IS MY WATER CLOUDY OR MILKY IN APPEARANCE WHEN IT COMES OUT OF THE TAP?

Water that appears cloudy or milky is typically caused by trapped air (very small air bubbles) in the water. If this occurs, simply let the water stand for a few minutes—the air will dissipate leaving a clear glass of water.

The quality of your water depends on the source water itself as well as factors such as the geology and biology of the area where the water came from. For some elements that are known to have an effect on the aesthetics of the water quality parameters, the EPA has established guidance levels known as secondary maximum contaminant level standards (SMCLs). When levels of these contaminants are found to be above the SMCLs, they may impact the aesthetic quality of the water (e.g., color, taste and odor). Although aesthetic water qualities may vary, your water meets all state and federal regulatory standards and is safe to use for all drinking water purposes. Secondary contaminants include, but are not limited to, manganese, iron and total dissolved solids (TDS).

WHY IS CHLORINE ADDED TO MY DRINKING WATER?

Chlorine is added to your water for your protection and is used as a disinfectant to ensure that harmful organisms, such as bacteria and viruses, are destroyed in the treatment process.

ARE THERE OTHER WAYS TO REMOVE THE CHLORINE TASTE OR SMELL FROM MY WATER?

To remove the taste of chlorine from your water, try these tips:

- Place water in a glass container in the refrigerator overnight, uncovered. This will let the chlorine dissipate.
- Bring your water to a rolling boil for five minutes and let it stand to cool.
- Add a slice of lemon or a few drops of lemon juice to your glass of drinking water.



WILL MY HOME TREATMENT DEVICE REMOVE CHLORINE?

Some home treatment devices can remove chlorine. Once chlorine is removed, the water should be treated like any other beverage product and used as quickly as possible. We recommend that you follow the manufacturer’s instructions for maintaining the device to ensure water quality.

Definition of Terms

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

GPG (grains per gallon): Used to describe the dissolved hardness minerals contained in water and is a unit of weight that equals 1/7,000 of a pound.

HAA5 (Haloacetic Acids): Consist of Monochloroacetic Acid, Dichloroacetic Acid, Trichloroacetic Acid, Bromoacetic Acid and Dibromoacetic Acid.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MNR: Monitored, not regulated.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not Applicable.

ND: None Detected.

NTU: Nephelometric turbidity units.

ppb (Parts per Billion): One part substance per billion parts water (or micrograms per liter).

pCi/L (Picocuries per Liter): Measurement of the natural rate of disintegration of radioactive contaminants in water (also beta particles).



ppm (Parts per Million): One part substance per million parts water (or milligrams per liter).

ppt (Parts per Trillion): One part substance per trillion parts water (or nanograms per liter).

Polyfluoroalkyl substances - PFAS: Widely used, long lasting chemicals, components of which break down very slowly over time. There are thousands of PFAS chemicals, and they are found in many different consumer, commercial, and industrial products.

SMCL (Secondary Maximum Contaminant Level): Non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects in drinking water.

Total Dissolved Solids: An overall indicator of the amount of minerals in water.

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

TTHM (Total Trihalomethanes): Consist of Chloroform, Bromoform, Bromodichloromethane and Dibromochloromethane.

UCMR (Unregulated Contaminant Monitoring Rule): Unregulated substances are measured, but maximum contaminant levels have not been established by the government.

What's in Your Water

HOW TO READ YOUR WATER QUALITY TABLE

Below, you'll see an analysis of your drinking water.
Here's an example of how to read these tables:



Start here and read across	2024 or year prior	The goal level for that substance	Highest level of substance allowed	Highest amount that was found	Highest and lowest amounts found	Yes means the amount found is below gov't requirements	Where substance usually originates
Substance (units)	Year Sampled	MCLG	MCL	Highest Amount Detected	Range of Detections	Compliance Achieved	Typical Sources

YOUR WATER QUALITY TABLE

The data shown in the tables below are results from commercial laboratories certified in drinking water analysis by the Arizona Department of Health Services. The table shows what substances were detected in your drinking water during 2024 or the last required sampling period within the last five years.

Regulated Substances Measured in the Water Leaving the Treatment Facility

LAKE HAVASU

Substance (units)	Year Sampled	MCLG	MCL	Highest Amount Detected	Range of Detections	Compliance Achieved	Typical Sources
Arsenic (ppb)	2024	0	10	6.8 ¹	ND - 6.8	YES	Erosion of natural deposits
Barium (ppm)	2024	2	2	0.018	0.018	YES	Erosion of natural deposits
Chromium (ppb)	2024	100	100	15	15	YES	Erosion of natural deposits
Fluoride (ppm)	2024	4	4.0	2.9 ²	2.9	YES	Erosion of natural deposits
Nitrate (ppm)	2024	10	10	1.5	1.5	YES	Runoff from fertilizer use; leaching from septic tanks
Gross Alpha excluding Radon and Uranium (pCi/L)	2020	0	15	2.8	2.8	YES	Erosion of natural deposits
Sodium	2024	NA	NM ²	210	210	YES	Erosion of natural deposits

What's in Your Water

Regulated Substances Measured in the Distribution System

LAKE HAVASU

Substance (units)	Year Sampled	MCLG/ MRDLG	MCL/ MRDL	Highest Running Annual Average	Range of Detections	Compliance Achieved	Typical Sources
TTHMs (ppb)	2023	NA ³	80	18.3	1.0 - 18.3	YES	By-product of drinking water disinfection
Chlorine residual (ppm)	2023	4	4.0	0.62	0.38 - 0.71	YES	Water additive used to control microbes

Tap Water Samples: Lead and Copper Results

LAKE HAVASU

Substance (units)	Year Sampled	MCLG	Action Level	Number of Samples	90th Percentile	Number of Samples Above Action Level	Compliance Achieved	Typical Sources
Copper (ppm)	2022	1.3	1.3	20	0.097	0	YES	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	2022	0	15	20	ND	0	YES	Corrosion of household plumbing systems; erosion of natural deposits

¹Arsenic: EPCOR's Lake Havasu groundwater arsenic removal facility continues to produce water with arsenic levels below the current federal and state standards. While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

²Elevated Fluoride Levels detected: This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children who drink water containing more than 2 milligrams per liter (mg/L) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by EPCOR has an average fluoride concentration of 2.1 mg/L. Dental fluorosis, in its moderate or severe forms, may result in brown staining and/or pitting of the permanent teeth. This problem occurs only in the developing teeth, before they erupt from the gums. Children under nine years of age should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water. Drinking water containing more than 4 mg/L of fluoride (the U.S. Environmental Protection Agency's drinking water standard) can increase your risk of developing bone disease. Your drinking water does not contain more than 4 mg/L of fluoride, but we're required to notify you when we discover that the fluoride levels in your drinking water exceed 2 mg/L because of the cosmetic dental problem. Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call **NSF International** at **1-877-867-3435**.

³TTHM/HAA5: Although there is no collective MCLG for this contaminant group, there are individual MCLGs for some of the individual contaminants: Trihalomethanes: bromodichloromethane (0.0 mg/L); bromoform (0.0 mg/L); chloroform (0.07 mg/L); dibromochloromethane (0.06 mg/L). Haloacetic acids: dichloroacetic acid (0.0 mg/L); trichloroacetic acid (0.3 mg/L). Monochloroacetic acid, bromoacetic acid and dibromoacetic acid are regulated with this group but have no MCLGs.

What's in Your Water

Regulated Substances Measured in the Water Leaving the Treatment Facility

MOOVAYLA KEYS

Substance (units)	Year Sampled	MCLG	MCL	Highest Amount Detected	Range of Detections	Compliance Achieved	Typical Sources
Arsenic (ppb)	2020	0	10	2.9	2.9	Yes	Erosion of natural deposits
Barium (ppm)	2020	2	2	0.12	0.12	Yes	Erosion of natural deposits
Fluoride (ppm)	2020	4.0	4.0	0.33	0.33	Yes	Erosion of natural deposits
Nitrate (ppm)	2024	10	10	0.37	0.37	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	2020	50	50	3.5	3.5	Yes	Erosion of natural deposits
Sodium (ppm)	2024	NA	NA	110	110	Yes	Erosion of natural deposits

Turbidity¹ – A Measure of the Clarity of the Water at the Treatment Facility

MOOVAYLA KEYS

Plant	Year Sampled	Limit (Treatment Technique)	Level Detected	Violation	Compliance Achieved	Typical Sources
Highest single turbidity measurement	2024	1 NTU	0.85 NTU ¹	No	Yes	Soil run-off
Lowest Monthly % Meeting Limit	2024	95% of samples < 0.3 NTU	98.3%	No	Yes	Soil run-off

Regulated Substances Measured in the Distribution System

MOOVAYLA KEYS

Substance (units)	Year Sampled	MCLG/ MRDLG	MCL/ MRDL	Highest Running Annual Average	Range of Detections	Violation	Compliance Achieved	Typical Sources
TTHMs (ppb)	2024	NA ²	80	62	33.2 - 89.1 ³	No	Yes	By-product of drinking water disinfection
HAA5 (ppb)	2024	NA ²	60	24	6.7 - 38	No	Yes	By-product of drinking water disinfection
Chlorine residual (ppm)	2024	4	4.0	1.02	0.68 - 1.25	No	Yes	Water additive used to control microbes

Tap Water Samples: Lead and Copper Results

MOOVAYLA KEYS

Substance (units)	Year Sampled	MCLG	Action Level	Number of Samples	90th Percentile	Number of Samples Above Action Level	Compliance Achieved	Typical Sources
Copper (ppm)	2023	1.3	1.3	10	0.87	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	2023	0	15	10	6.2	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits

What's in Your Water

Regulated Substances Measured in the Water Leaving the Treatment Facility

LAKESIDE

Substance (units)	Year Sampled	MCLG	MCL	Highest Amount Detected	Range of Detections	Compliance Achieved	Typical Sources
Arsenic (ppb)	2020	0	10	2.8	2.8	Yes	Erosion of natural deposits
Barium (ppm)	2020	2	2	0.12	0.12	Yes	Erosion of natural deposits
Fluoride (ppm)	2020	4.0	4.0	0.33	0.33	Yes	Erosion of natural deposits
Nitrate (ppm)	2024	10	10	0.36	0.36	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	2020	50	50	3.3	3.3	Yes	Erosion of natural deposits
Sodium (ppm)	2024	NA	NA	110	110	Yes	Erosion of natural deposits

Turbidity¹ – A Measure of the Clarity of the Water at the Treatment Facility

LAKESIDE

Plant	Year Sampled	Limit (Treatment Technique)	Level Detected	Violation	Compliance Achieved	Typical Sources
Highest single turbidity measurement	2024	1 NTU	0.96 NTU ¹	No	Yes	Soil run-off
Lowest Monthly % Meeting Limit	2024	95% of samples < 0.3 NTU	97.1%	No	Yes	Soil run-off

Regulated Substances Measured in the Distribution System

LAKESIDE

Substance (units)	Year Sampled	MCLG/ MRDLG	MCL/ MRDL	Highest Running Annual Average	Range of Detections	Violation	Compliance Achieved	Typical Sources
TTHMs (ppb)	2024	NA ²	80	65	41.6 - 81.3 ³	No	Yes	By-product of drinking water disinfection
HAA5 (ppb)	2024	NA ²	60	15	7.4 - 25.4	No	Yes	By-product of drinking water disinfection
Chlorine residual (ppm)	2024	4	4.0	0.68	0.19 - 1.25	No	Yes	Water additive used to control microbes

Tap Water Samples: Lead and Copper Results

LAKESIDE

Substance (units)	Year Sampled	MCLG	Action Level	Number of Samples	90th Percentile	Number of Samples Above Action Level	Compliance Achieved	Typical Sources
Copper (ppm)	2023	1.3	1.3	10	0.15	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	2023	0	15	10	ND	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits

What's in Your Water

Regulated Substances Measured in the Water Leaving the Treatment Facility

MARINA VILLAGE

Substance (units)	Year Sampled	MCLG	MCL	Highest Amount Detected	Range of Detections	Compliance Achieved	Typical Sources
Arsenic (ppb)	2020	0	10	2.7	2.7	Yes	Erosion of natural deposits
Barium (ppm)	2020	2	2	0.12	0.12	Yes	Erosion of natural deposits
Fluoride (ppm)	2020	4.0	4.0	0.33	0.33	Yes	Erosion of natural deposits
Nitrate (ppm)	2024	10	10	0.38	0.38	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	2020	50	50	3	3	Yes	Erosion of natural deposits
Sodium (ppm)	2024	NA	NA	110	110	Yes	Erosion of natural deposits
Gross alpha excluding radon and uranium (pCi/L)	2022	0	15	3	3	Yes	Erosion of natural deposits

Turbidity¹ – A Measure of the Clarity of the Water at the Treatment Facility

MARINA VILLAGE

Plant	Year Sampled	Limit (Treatment Technique)	Level Detected	Violation	Compliance Achieved	Typical Sources
Highest single turbidity measurement	2024	1 NTU	0.67 NTU ¹	No	Yes	Soil run-off
Lowest Monthly % Meeting Limit	2024	95% of samples < 0.3 NTU	99.2%	No	Yes	Soil run-off

Regulated Substances Measured in the Distribution System

MARINA VILLAGE

Substance (units)	Year Sampled	MCLG/ MRDLG	MCL/ MRDL	Highest Running Annual Average	Range of Detections	Violation	Compliance Achieved	Typical Sources
TTHMs (ppb)	2024	NA ²	80	73	36 - 107 ³	No	Yes	By-product of drinking water disinfection
HAA5 (ppb)	2024	NA ²	60	21	11.6 - 41	No	Yes	By-product of drinking water disinfection
Chlorine residual (ppm)	2024	4	4.0	1.09	0.67 - 1.76	No	Yes	Water additive used to control microbes

Tap Water Samples: Lead and Copper Results

MARINA VILLAGE

Substance (units)	Year Sampled	MCLG	Action Level	Number of Samples	90th Percentile	Number of Samples Above Action Level	Compliance Achieved	Typical Sources
Copper (ppm)	2023	1.3	1.3	10	0.1	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	2023	0	15	10	ND	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits

What's in Your Water

Regulated Substances Measured in the Water Leaving the Treatment Facility

PARKER DAM

Substance (units)	Year Sampled	MCLG	MCL	Highest Amount Detected	Range of Detections	Compliance Achieved	Typical Sources
Arsenic (ppb)	2020	0	10	2.7	2.7	Yes	Erosion of natural deposits
Barium (ppm)	2020	2	2	0.12	0.12	Yes	Erosion of natural deposits
Fluoride (ppm)	2020	4.0	4.0	0.34	0.34	Yes	Erosion of natural deposits
Nitrate (ppm)	2024	10	10	0.38	0.38	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	2020	50	50	3.3	3.3	Yes	Erosion of natural deposits
Sodium (ppm)	2024	NA	NA	110	110	Yes	Erosion of natural deposits
Gross alpha excluding radon and uranium (pCi/L)	2022	0	15	3	3	Yes	Erosion of natural deposits

Turbidity¹ – A Measure of the Clarity of the Water at the Treatment Facility

PARKER DAM

Plant	Year Sampled	Limit (Treatment Technique)	Level Detected	Violation	Compliance Achieved	Typical Sources
Highest single turbidity measurement	2024	1 NTU	0.88 NTU ¹	No	Yes	Soil run-off
Lowest Monthly % Meeting Limit	2024	95% of samples < 0.3 NTU	98.7%	No	Yes	Soil run-off

Regulated Substances Measured in the Distribution System

PARKER DAM

Substance (units)	Year Sampled	MCLG/ MRDLG	MCL/ MRDL	Highest Running Annual Average	Range of Detections	Violation	Compliance Achieved	Typical Sources
TTHMs (ppb)	2024	NA ²	80	63.8	28.7 - 67.3	No	Yes	By-product of drinking water disinfection
HAA5 (ppb)	2024	NA ²	60	18	6.9 - 21.5	No	Yes	By-product of drinking water disinfection
Chlorine residual (ppm)	2024	4	4.0	0.75	0.02 - 0.97	No	Yes	Water additive used to control microbes

Tap Water Samples: Lead and Copper Results

PARKER DAM

Substance (units)	Year Sampled	MCLG	Action Level	Number of Samples	90th Percentile	Number of Samples Above Action Level	Compliance Achieved	Typical Sources
Copper (ppm)	2023	1.3	1.3	10	0.12	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	2023	0	15	10	ND	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits

What's in Your Water

Regulated Substances Measured in the Water Leaving the Treatment Facility

RIO LINDO

Substance (units)	Year Sampled	MCLG	MCL	Highest Amount Detected	Range of Detections	Compliance Achieved	Typical Sources
Arsenic (ppb)	2020	0	10	2.6	2.6	Yes	Erosion of natural deposits
Barium (ppm)	2020	2	2	0.11	0.11	Yes	Erosion of natural deposits
Fluoride (ppm)	2020	4.0	4.0	0.34	0.34	Yes	Erosion of natural deposits
Nitrate (ppm)	2024	10	10	0.37	0.37	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	2020	50	50	2.9	2.9	Yes	Erosion of natural deposits
Sodium (ppm)	2024	NA	NA	110	110	Yes	Erosion of natural deposits
Gross alpha excluding radon and uranium (pCi/L)	2022	0	15	3	3	Yes	Erosion of natural deposits
Combined Radium (226/228) (pCi/L)	2022	0	5	0.7	0.7	Yes	Erosion of natural deposits

Turbidity¹ – A Measure of the Clarity of the Water at the Treatment Facility

RIO LINDO

Plant	Year Sampled	Limit (Treatment Technique)	Level Detected	Violation	Compliance Achieved	Typical Sources
Highest single turbidity measurement	2024	1 NTU	0.68 NTU ¹	No	Yes	Soil run-off
Lowest Monthly % Meeting Limit	2024	95% of samples < 0.3 NTU	97.8%	No	Yes	Soil run-off

Regulated Substances Measured in the Distribution System

RIO LINDO

Substance (units)	Year Sampled	MCLG/ MRDLG	MCL/ MRDL	Highest Running Annual Average	Range of Detections	Violation	Compliance Achieved	Typical Sources
TTHMs (ppb)	2024	NA ²	80	66.9	63.5 - 66.9	No	Yes	By-product of drinking water disinfection
HAA5 (ppb)	2024	NA ²	60	20.8	20.7 - 20.8	No	Yes	By-product of drinking water disinfection
Chlorine residual (ppm)	2024	4	4.0	1.01	0.58 - 1.37	No	Yes	Water additive used to control microbes

Tap Water Samples: Lead and Copper Results

RIO LINDO

Substance (units)	Year Sampled	MCLG	Action Level	Number of Samples	90th Percentile	Number of Samples Above Action Level	Compliance Achieved	Typical Sources
Copper (ppm)	2023	1.3	1.3	5	0.17	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	2023	0	15	5	ND	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits

What's in Your Water

Regulated Substances Measured in the Water Leaving the Treatment Facility

HOLIDAY HARBOR

Substance (units)	Year Sampled	MCLG	MCL	Highest Amount Detected	Range of Detections	Compliance Achieved	Typical Sources
Arsenic (ppb)	2020	0	10	2.8	2.8	Yes	Erosion of natural deposits
Barium (ppm)	2020	2	2	0.11	0.11	Yes	Erosion of natural deposits
Fluoride (ppm)	2020	4.0	4.0	0.33	0.33	Yes	Erosion of natural deposits
Nitrate (ppm)	2024	10	10	0.38	0.38	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	2020	50	50	3.5	3.5	Yes	Erosion of natural deposits
Sodium (ppm)	2024	NA	NA	110	110	Yes	Erosion of natural deposits
Gross alpha excluding radon and uranium (pCi/L)	2022	0	15	3.6	3.6	Yes	Erosion of natural deposits

Turbidity¹ – A Measure of the Clarity of the Water at the Treatment Facility

HOLIDAY HARBOR

Plant	Year Sampled	Limit (Treatment Technique)	Level Detected	Violation	Compliance Achieved	Typical Sources
Highest single turbidity measurement	2024	1 NTU	0.73 NTU ¹	No	Yes	Soil run-off
Lowest Monthly % Meeting Limit	2024	95% of samples < 0.3 NTU	99%	No	Yes	Soil run-off

Regulated Substances Measured in the Distribution System

HOLIDAY HARBOR

Substance (units)	Year Sampled	MCLG/ MRDLG	MCL/ MRDL	Highest Running Annual Average	Range of Detections	Violation	Compliance Achieved	Typical Sources
TTHMs (ppb)	2024	NA ²	80	57.5	36.2 - 86.7 ³	No	Yes	By-product of drinking water disinfection
HAA5 (ppb)	2024	NA ²	60	13	7.1 - 16.7	No	Yes	By-product of drinking water disinfection
Chlorine residual (ppm)	2024	4	4.0	0.54	0.02 - 0.78	No	Yes	Water additive used to control microbes

Tap Water Samples: Lead and Copper Results

HOLIDAY HARBOR

Substance (units)	Year Sampled	MCLG	Action Level	Number of Samples	90th Percentile	Number of Samples Above Action Level	Compliance Achieved	Typical Sources
Copper (ppm)	2023	1.3	1.3	10	0.065	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	2023	0	15	10	ND	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits

What's in Your Water

¹**Turbidity** has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

²**TTHM/HAA5:** Although there is no collective MCLG for this contaminant group, there are individual MCLGs for some of the individual contaminants: Trihalomethanes: bromodichloromethane (0.0 mg/L); bromoform (0.0 mg/L); chloroform (0.07 mg/L); dibromochloromethane (0.06 mg/L). Haloacetic acids: dichloroacetic acid (0.0 mg/L); trichloroacetic acid (0.0 mg/L); monochloroacetic acid, bromoacetic acid and dibromoacetic acid are regulated with this group but have no MCLGs.

³**TTHM/HAA5:** Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

ADDITIONAL MONITORING

In addition to the parameters listed in this table, other parameters were monitored for, including regulated pesticides, herbicides, petroleum by-products and metals. None of those parameters were detected in the water. If you have any questions about this report or your drinking water, please call our **Customer Care** team at **1-800-383-0834**.

EPCOR encourages feedback related to the quality of water that is provided to you. Please feel free to submit comments to us directly at mywater@epcor.com. You may also provide feedback to the Arizona Corporation Commission (ACC).

epcor.com