

Parameter (Units)	#	Mean	Range	YTD #	YTD Mean	YTD Range
Cellular ATP (pg/mL)	152	0.6	<0.10 - 8.3	1048	0.3	<0.10 - 10.0
Chlorine total (mg/L)	244	1.56	0.97 - 2.20	1826	1.77	0.19 - 2.34
Coliforms total (MPN/100 mL)	12	Not Detected	Not Detected	26	Not Detected	Not Detected
Coliforms total (PA/100mL)	236	-VE	+VE	1803	-VE	+VE - -VE
E. coli (MPN/100 mL)	12	Not Detected	Not Detected	26	Not Detected	Not Detected
E. coli (PA/100mL)	236	-VE	-VE	1803	-VE	-VE
Turbidity (NTU)	244	0.28	<0.04 - 3.51	1826	0.22	<0.04 - 6.84

