

[illegible]

RWW	Untreated Influent into the plant
INF	Untreated wastewater from collection system
INFs	Influent, screened at the Headworks Division Structure
PE	Primary Effluent from conventional primaries
PE 30	Primary Effluent from conventional primaries discharged via Outfall 30
EPT	Enhanced Primary Treatment
EPE	Enhanced Primary Effluent
EPEPS	Enhanced Primary Effluent Pump Station
FE	Final Effluent from secondary treatment process (with biological nutrient removal). Pre-Ultraviolet disinfection.

FEC	Combined post-UV disinfection (FE+EPEPS)
CUTALL 10	UV-Disinfected, discharged via CUTALL 10
CUTALL 20	Combined Bypass (RAW + FE + EPE)
CUTALL 30	Combined Bypass (INF + INF3 + PE30 + EPE)
MPW	Membrane Product Water (Effluent re-use water)
ML	Megalitre (1,000,000 Litre)
MPN	Most Probable Number
NR	No Result
NS	No Sample
INS	Insufficient Sample
ACP	Alberta Environment & Parks

Report Comments	
AEP Ref #	

Jamie Gingrich P.Eng.
Senior Manager, WWTP Operations

Paul Jacquier MBA, EMSc.
Senior Manager, Analytical Operations