


**NOTE:**

1. 3000 mm CLEARANCE REQUIRED IN FRONT OF ANY DOOR FOR HIGH VOLTAGE OPERATION.

20170126 14:49 r lawrie

  
**CUSTOMER CONNECTION  
GUIDE**

GROUND GRID REQUIREMENTS FOR 15 kV &  
25 kV SWITCHING CUBICLES AND THREE  
PHASE TRANSFORMERS NEXT TO EACH OTHER

DATE REVISED:  
2017-01-23

DRAWING NO. :  
010

REFERENCE NO.  
**66 CC 07 00 60 002**

PAGE NO.  
1 / 1