


LEGEND

- | | | |
|---|---|--|
| <p>— PRIMARY CONDUCTOR
1-100C C/W 1-1/C #1/0 AL XLPE 25KV</p> <p>- - - SECONDARY CONDUCTOR
2-100C E/W 1-2/C #4/0 AL XLPE</p> <p>· · · SECONDARY CONDUCTOR
1-100C E/W 1-2/C #4/0 AWG AL XLPE</p> | <p>- - - SECONDARY CONDUCTOR
1-100C C/W 1-2/C #2/0 AL XLPE
TO EACH FOUR GANG METER BASE</p> <p>WP HOUSE PANEL AND METER</p> <p>△ SERVICE PEDESTAL
P7 C/W 2P-400A MAIN BREAKER
ALL OTHERS C/W 2P-400A MAIN BREAKER</p> | <p>☐ PADMOUNTED TRANSFORMER
C/W POSTS & GUARDRAIL</p> <p>■ SWITCHING CUBICLE</p> <p>■ FOUR GANG METER BASE</p> <p>-U- UTILITIES
W - WATER
D - DRAINAGE
S - SEWER</p> |
|---|---|--|

NOTES:

1. INDIVIDUAL SERVICE CABLES NOT SHOWN ON THIS EXAMPLE
2. DUCT IS REQUIRED UNDER ROADWAYS AND DRIVEWAYS
3. FOR SITES WITH MORE THAN TWO TRANSFORMERS A PRIMARY LOOP IS REQUIRED

20170126 14:05 r lawrie

 <p style="font-size: 1.2em; font-weight: bold; margin-top: 10px;">CUSTOMER CONNECTION GUIDE</p>		<p style="font-size: 1.1em;">SAMPLE OF SUBMISSION FOR MULTI-FAMILY DEVELOPMENTS (FOR EXAMPLE PURPOSES ONLY)</p>	
DATE REVISED: 2014-09-29	DRAWING NO. : 012	REFERENCE NO. 60 CC 07 00 23 001	PAGE NO. 1 / 1