

NOTE: MAXIMUM DISTANCE ABOVE ROOFLINE OR TOP SUPPORT FOR:

100A RESIDENTIAL SERVICE:

- 450 mm FOR 35mm (1-1/4") MAST
- 600 mm FOR 41mm (1-1/2") MAST
- 900 mm FOR 53mm (2") MAST

150A or 200A RESIDENTIAL SERVICE:


- 900 mm FOR 53mm (2") MAST

IN ALL CASES SERVICE ATTACHMENT TO BE ON THE POLE LINE SIDE OF THE BUILDING.

A MINIMUM 3m HORIZONTAL CLEARANCE IS REQUIRED BETWEEN THE SERVICE POLE AND THE BUILDING SERVICE ATTACHMENT POINT.

INSTALLATION AS PER CEC PART 1

20170330 09:55 r lawrie



TYPICAL RESIDENTIAL AERIAL SERVICE
INSTALLATION (MAXIMUM SERVICE SPAN
DISTANCE 30 m)

DATE REVISED: 2017-03-30	DRAWING NO. : 016	REFERENCE NO. 61 CC 07 00 91 100	PAGE NO. 1 / 1
-----------------------------	----------------------	-------------------------------------	-------------------