



NOTE: MAXIMUM DISTANCE ABOVE ROOFLINE OR TOP SUPPORT FOR:

100A RESIDENTIAL SERVICE:

- 450 mm FOR 35mm (1-1/4") MAST
- 600 mm FOR 41mm (1-1/2") MAST
- 900 mm FOR 53mm (2") MAST

150A OR 200A RESIDENTIAL SERVICE:

- 900 mm FOR 53mm (2") MAST

IN ALL CASES SERVICE ATTACHMENT TO BE ON THE POLE LINE SIDE OF THE BUILDING

INSTALLATION AS PER CEC PART 1

20170329 14:34 r lawrie

EPCOR
 CUSTOMER CONNECTION
 GUIDE

TYPICAL RESIDENTIAL AERIAL SERVICE
 ATTACHMENT DETAILS
 (MAXIMUM DISTANCE 30 METERS)
 SERVICE ATTACHMENT TO BE ON THE
 POLE LINE SIDE OF THE BUILDING

DATE REVISED:
 2017-03-29

DRAWING NO. :
 017

REFERENCE NO.
 61 CC 07 00 91 001

PAGE NO.
 1 / 1