DRAWING 15:
HEAVY DUTY ATTACHMENT DEVICES



4 SPOOL RACK
ASSEMBLY



3 SPOOL RACK
ASSEMBLY

WALL CLEVIS ASSEMBLY AND INSTALLATION

UP TO 200A RESIDENTIAL
UP TO 150A COMMERCIAL

PREFFRRED METHOD



CLEVIS ASSEMBLY
AND INSTALLATION
UP TO 200A RESIDENTIAL
UP TO 150A COMMERCIAL

ALTERNATE METHOD





NOTES:

1. CLEVIS MUST BE INSTALLED THROUGH MIN 50mm THICK MATERIAL (NOT THROUGH FACIA BOARD)
2. MIMIMUM CLEARANCES TO GROUND MUST BE MAINTAINED
   - MINIMUM CLEARANCE 3500mm
   - MAXIMUM CLEARANCE 6000mm

EPCOR CUSTOMER CONNECTION GUIDE		HEAVY DUTY ATTACHMENT DEVICES	
DATE REVISED: 2014-09-29	DRAWING NO.: 015	REFERENCE NO. 61 CC 07 00 22 100	PAGE NO. 1/1