

**TABLE 2:
MAXIMUM HORSEPOWER OF MOTORS PERMITTED**

RATING OF MAIN SERVICE CONDUCTORS (AMPS)	208Y VOLTS	240 VOLTS 3-PHASE	480Y VOLTS	600Y VOLTS
100 A	10	10	25	30
200 A	20	20	50	50
300 A	30	30	75	100
400 A	40	40	100	125
600 A	60	*	150	200
800 A	75	*	200	200
1,200 A	100	*	200	200
1,600 A	125	*	200	200
2,000 A	150	*	200	200

* Special permission is required prior to construction approval for motors larger than those indicated in the table. Please contact EDTI Customer Engineering Services for more information.