

2.2.1 Bacteriological Data: Water Treatment Plants

April 2016

Treated Water Entering the Distribution System

	ROSSDALE			E.L. SMITH			YTD (combined)			Limit	Unit
	# Samples	# +ve	% +ve	# Samples	# +ve	% +ve	# Samples	# +ve	% +ve	Approval	
Coliforms, total	30	0	0	30	0	0	244	1	0	0/100 mL	PA/100 mL
E. coli	30	0	0	30	0	0	244	1	0	0/100 mL	PA/100 mL
Heterotrophic Plate Count	30	0	0	30	0	0	243	5	2	N/A	CFU/mL

Water Entering the Plant Reservoir

	ROSSDALE			E.L. SMITH			YTD (combined)			Limit	Unit
	# Samples	# +ve	% +ve	# Samples	# +ve	% +ve	# Samples	# +ve	% +ve	Approval	
Coliforms, total	30	0	0	30	0	0	244	0	0	N/A	PA/100 mL
E. coli	30	0	0	30	0	0	244	0	0	N/A	PA/100 mL
Heterotrophic Plate Count	30	0	0	30	0	0	243	1	0	N/A	CFU/mL

Raw River Water Entering the Treatment Plants

	ROSSDALE			E.L. SMITH			YTD (combined)			Limit	Unit
	# Samples	# +ve	% +ve	# Samples	# +ve	% +ve	# Samples	# +ve	% +ve	Approval	
Coliforms, total	30	30	100	4	4	100	140	140	100	N/A	MPN/100 mL
E. coli	30	30	100	4	4	100	140	140	100	N/A	MPN/100 mL
Heterotrophic Plate Count	1	1	100	1	1	100	7	7	100	N/A	CFU/mL

January: Incorrect sampling procedure produced a false *E. coli* result at E.L. Smith WTP.

2.2.2 Bacteriological Data: Distribution System

April 2016

	Coliforms, total			E. coli			HPC		
	Count	# +ve	% +ve	Count	# +ve	% +ve	Count	# +ve	% +ve
January									
FIELD DISTRIBUTION	115	0	0.0	115	0	0.0	115	9	7.8
FIELD DISTRIBUTION - PLPH	54	0	0.0	54	0	0.0	0		0.0
FIELD RESERVOIR	48	0	0.0	48	0	0.0	48	1	2.1
FIELD RESERVOIR - PLPH (duplicate-not counted)	48	0	0.0	48	0	0.0	0		0.0
Monthly	217	0	0.0	217	0	0.0	163	10	6.1
February									
FIELD DISTRIBUTION	110	0	0.0	110	0	0.0	110	1	0.9
FIELD DISTRIBUTION - PLPH	54	0	0.0	54	0	0.0	0		0.0
FIELD RESERVOIR	47	0	0.0	47	0	0.0	47	0	0.0
FIELD RESERVOIR - PLPH (duplicate-not counted)	47	0	0.0	47	0	0.0	0		0.0
Monthly	211	0	0.0	211	0	0.0	157	1	0.6
March									
FIELD DISTRIBUTION	107	0	0.0	107	0	0.0	107	2	1.9
FIELD DISTRIBUTION - PLPH	54	0	0.0	54	0	0.0	0		0.0
FIELD RESERVOIR	60	0	0.0	60	0	0.0	60	2	3.3
FIELD RESERVOIR - PLPH (duplicate-not counted)	59	0	0.0	59	0	0.0	0		0.0
Monthly	221	0	0.0	221	0	0.0	167	4	2.4
April									
FIELD DISTRIBUTION	110	0	0.0	110	0	0.0	110	1	0.9
FIELD DISTRIBUTION - PLPH	54	0	0.0	54	0	0.0	0		0.0
FIELD RESERVOIR	44	0	0.0	44	0	0.0	44	2	4.5
FIELD RESERVOIR - PLPH (duplicate-not counted)	33	0	0.0	33	0	0.0	0		0.0
Monthly	208	0	0.0	208	0	0.0	154	3	1.9
Year to Date	857	0	0.0	857	0	0.0	641	18	2.8

Guidelines for Canadian Drinking Water Quality recommend 178 bacteriological samples for a city the size of Edmonton. HPC are not required.

Testing conducted by Laboratory for Public Health are labelled with PLPH.

2.2.2 Bacteriological Data: Distribution System

April 2016

Samples from Depressurizations

	Coliforms, total			E. coli		
	Count	# +ve	% +ve	Count	# +ve	% +ve
January	46	0	0.0	46	0	0.0
February	50	0	0.0	50	0	0.0
March	70	0	0.0	70	0	0.0
April	72	0	0.0	72	0	0.0
YTD	238	0	0.0	238	0	0.0

Samples from Complaints

	Coliforms, total			E. coli			Heterotrophic Plate Count		
	Count	# +ve	% +ve	Count	# +ve	% +ve	Count	# +ve	% +ve
January	11	0	0.0	11	0	0.0	11	0	0.0
February	12	0	0.0	12	0	0.0	12	0	0.0
March	16	0	0.0	16	0	0.0	16	0	0.0
April	17	0	0.0	17	0	0.0	17	0	0.0
YTD	56	0	0.0	56	0	0.0	56	0	0.0