PROVIDING MORE EPCOR

Gold Bar Wastewater Treatment Plant
Plant Performance Report
November 2020

Digested Sludge: Total Monthly Volume (ML)	63.6

Volume of Flow (ML)

DATE	Peak Flow (MLD)	Influent: INFs	Influent: RAW	Effluent: Non UV Disinfected: OUTFALL 30	Effluent: Non UV Disinfected: OUTFALL 20	Effluent: Non UV Disinfected: MPW	Effluent: UV Disinfected: EPEPS	Effluent: UV Disinfected: OUTFALL 10: FEC	Effluent: UV Disinfected: OUTFALL 10: FE
Sun-01	365.4	0.0	257.7	0.0	0.0	12.7	0.0	245.0	245.0
Mon-02	338.3	0.0	251.4	0.0	0.0	10.5	0.0	240.9	240.9
Tue-03	332.4	0.0	247.0	0.0	0.0	11.7	0.0	235.3	235.3
Wed-04	333.1	0.0	249.5	0.0	0.0	11.8	0.0	237.7	237.7
Thu-05	616.8	0.0	284.9	21.7	0.0	12.1	0.0	251.1	251.1
Fri-06	372.2	0.0	252.8	0.0	0.0	11.9	0.0	240.9	240.9
Sat-07	351.0	0.0	247.3	0.0	0.0	12.2	0.0	235.1	235.1
Sun-08	363.5	0.0	253.6	0.0	0.0	12.2	0.0	241.4	241.4
Mon-09	342.1	0.0	255.4	0.0	0.0	11.5	0.0	243.9	243.9
Tue-10	368.1	0.0	256.7	0.0	0.0	10.9	0.0	245.8	245.8
Wed-11	395.8	0.0	242.9	0.0	0.0	11.3	0.0	231.6	231.6
Thu-12	331.5	0.0	249.1	0.0	0.0	11.1	0.0	238.0	238.0
Fri-13	343.1	0.0	250.4	0.0	0.0	11.3	0.0	239.1	239.1
Sat-14	353.8	0.0	243.4	0.0	0.0	11.2	0.0	232.2	232.2
Sun-15	356.1	0.0	246.6	0.0	0.0	11.3	0.0	235.3	235.3
Mon-16	340.2	0.0	251.9	0.0	0.0	11.5	0.0	240.4	240.4
Tue-17	333.6	0.0	246.8	0.0	0.0	12.1	0.0	234.7	234.7
Wed-18	331.8	0.0	246.9	0.0	0.0	11.7	0.0	235.2	235.2
Thu-19	342.9	0.0	249.3	0.0	0.0	11.5	0.0	237.8	237.8
Fri-20	340.3	0.0	250.9	0.0	0.0	12.0	0.0	238.9	238.9
Sat-21	346.6	0.0	248.5	0.0	0.0	12.4	0.0	236.1	236.1
Sun-22	360.7	0.0	252.0	0.0	0.0	12.4	0.0	239.6	239.6
Mon-23	348.2	0.0	252.4	0.0	0.0	12.5	0.0	239.9	239.9
Tue-24	330.0	0.0	248.1	0.0	0.0	11.9	0.0	236.2	236.2
Wed-25	335.7	0.0	257.0	0.0	0.0	11.6	0.0	245.4	245.4
Thu-26	327.0	0.0	245.8	0.0	0.0	11.6	0.0	234.2	234.2
Fri-27	338.3	0.0	252.1	0.0	0.0	11.5	0.0	240.6	240.6
Sat-28	353.5	0.0	242.8	0.0	0.0	11.4	0.0	231.4	231.4
Sun-29	355.9	0.0	245.2	0.0	0.0	12.3	0.0	232.9	232.9
Mon-30	363.0	0.0	250.5	0.0	0.0	12.2	0.0	238.3	238.3
Average	357.0	0.0	251.0	0.7	0.0	11.7	0.0	238.5	238.5
Minimum	327.0	0.0	242.8	0.0	0.0	10.5	0.0	231.4	231.4
Maximum	616.8	0.0	284.9	21.7	0.0	12.7	0.0	251.1	251.1
GeoMean	---	---	---	---	---	---	---	---	---
TOTAL	---	0	7,529	22	0	352	0	7,155	7,155

Liquid Stream Quality

DATE	pH@25°C: RAW	pH@25°C: OUTFALL 30	pH@25°C: OUTFALL 20	pH@25°C: OUTFALL 10: FEC	TSS (mg/L): RAW	TSS (mg/L): OUTFALL 30	TSS (mg/L): OUTFALL 20	TSS (mg/L): EPEPS	TSS (mg/L): OUTFALL 10: FEC	TSS (mg/L): OUTFALL 10: FE
Sun-01	7.6			7.5	300				3.9	3.9
Mon-02	7.6			7.5	272				6.4	6.4
Tue-03	7.5			7.6	268				3.3	3.3
Wed-04	7.6			7.5	312				4.3	4.3
Thu-05	7.5	7.6		7.6	452	83			3.7	3.7
Fri-06	7.7			7.6	348				3.6	3.6
Sat-07	7.6			7.4	340				2.9	2.9
Sun-08	7.7			7.4	332				3.4	3.4
Mon-09	7.5			7.5	260				3.8	3.8
Tue-10	7.6			7.5	308				3.2	3.2
Wed-11	7.5			7.7	396				3.9	3.9
Thu-12	7.6			7.5	244				3.1	3.1
Fri-13	7.6			7.5	396				3.8	3.8
Sat-14	7.7			7.5	340				2.8	2.8
Sun-15	7.6			7.6	336				3.3	3.3
Mon-16	7.6			7.6	316				3.1	3.1
Tue-17	7.5			7.6	316				3.6	3.6
Wed-18	7.5			7.4	396				3.1	3.1
Thu-19	7.8			7.6	328				3.2	3.2
Fri-20	7.6			7.5	356				3.6	3.6
Sat-21	7.5			7.5	292				3.2	3.2
Sun-22	7.6			7.6	304				4.0	4.0
Mon-23	7.5			7.6	368				3.8	3.8
Tue-24	7.6			7.5	304				3.6	3.6
Wed-25	7.5			7.5	344				4.6	4.6
Thu-26	7.5			7.6	276				3.6	3.6
Fri-27	7.5			7.6	264				3.4	3.4
Sat-28	7.4			7.7	257				3.2	3.2
Sun-29	7.6			7.6	272				3.6	3.6
Mon-30	7.5			7.6	316				3.9	3.9
Average	7.6	7.6	---	7.5	320	83	---	---	3.6	3.6
Minimum	7.4	7.6	---	7.4	244	83	---	---	2.8	2.8
Maximum	7.8	7.6	---	7.7	452	83	---	---	6.4	6.4
GeoMean	---	---	---	---	---	---	---	---	---	---
TOTAL	---	---	---	---	---	---	---	---	---	---

DATE	BOD_5/$cBOD_5$ (mg/L): RAW	BOD_5: OUTFALL 30	BOD_5: OUTFALL 20	BOD_5: EPEPS	BOD_5: OUTFALL 10: FEC	BOD_5: OUTFALL 10: FE	TP (mg/L): RAW	TP (mg/L): OUTFALL 30	TP (mg/L): OUTFALL 20	TP (mg/L): EPEPS	TP (mg/L): OUTFALL 10: FEC	TP (mg/L): OUTFALL 10: FE
Sun-01	305				0.22	0.22	8.66				0.22	0.22
Mon-02	363				0.24	0.24	7.89				0.24	0.24
Tue-03	224				0.27	0.27	8.34				0.25	0.25
Wed-04	329				0.26	0.26	8.81				0.26	0.26
Thu-05	305	134			0.26	0.26	8.22	4.89			0.26	0.26
Fri-06	356				0.22	0.22	7.57				0.22	0.22
Sat-07	307				0.22	0.22	8.23				0.22	0.22
Sun-08	342				0.22	0.22	7.71				0.22	0.22
Mon-09	328				0.22	0.22	7.67				0.22	0.22
Tue-10	326				0.22	0.22	8.61				0.22	0.22
Wed-11	331				0.24	0.24	8.68				0.24	0.24
Thu-12	370				0.21	0.21	8.27				0.21	0.21
Fri-13	315				0.22	0.22	8.55				0.22	0.22
Sat-14	345				0.22	0.22	8.44				0.22	0.22
Sun-15	354				0.25	0.25	8.86				0.25	0.25
Mon-16	309				0.22	0.22	7.97				0.22	0.22
Tue-17	326				0.25	0.25	8.74				0.25	0.25
Wed-18	363				0.23	0.23	8.47				0.23	0.23
Thu-19	352				0.24	0.24	7.73				0.24	0.24
Fri-20	342				0.26	0.26	8.77				0.26	0.26
Sat-21	375				0.24	0.24	7.20				0.24	0.24
Sun-22	330				0.26	0.26	8.32				0.26	0.26
Mon-23	321				0.24	0.24	7.64				0.24	0.24
Tue-24	330				0.25	0.25	8.48				0.25	0.25
Wed-25	329				0.24	0.24	7.82				0.24	0.24
Thu-26	306				0.24	0.24	6.94				0.24	0.24
Fri-27	267				0.23	0.23	6.72				0.23	0.23
Sat-28	323				0.23	0.23	6.74				0.23	0.23
Sun-29	281				0.22	0.22	6.68				0.22	0.22
Mon-30	275				0.20	0.20	6.92				0.20	0.20
Average	324	134	---	---	0.23	0.23	7.99	4.89	---	---	0.23	0.23
Minimum	224	134	---	---	0.20	0.20	6.68	4.89	---	---	0.20	0.20
Maximum	375	134	---	---	0.27	0.27	8.86	4.89	---	---	0.27	0.27
GeoMean	---	---	---	---	---	---	---	---	---	---	---	---
TOTAL	---	---	---	---	---	---	---	---	---	---	---	---

DATE	NH3-N (mg/L): RAW	NH3-N (mg/L): OUTFALL 30	NH3-N (mg/L): OUTFALL 20	NH3-N (mg/L): EPEPS	NH3-N (mg/L): OUTFALL 10: FEC	NH3-N (mg/L): OUTFALL 10: FE	TKN (mg/L): RAW	TKN (mg/L): OUTFALL 30	TKN (mg/L): OUTFALL 20	TKN (mg/L): OUTFALL 10: FEC
Sun-01	40.8				1.12	1.12	62.4			3.10
Mon-02	41.6				0.77	0.77	58.2			2.50
Tue-03	42.0				0.25	0.25	59.7			1.90
Wed-04	41.2				0.26	0.26	60.2			1.60
Thu-05	33.8	37.7			0.44	0.44	57.1	48.0		2.20
Fri-06	36.1				0.37	0.37	55.7			2.10
Sat-07	33.3				0.83	0.83	62.3			2.30
Sun-08	38.6				1.50	1.50	54.7			2.90
Mon-09	36.7				0.87	0.87	59.4			3.00
Tue-10	38.0				0.26	0.26	69.1			2.00
Wed-11	38.7				0.59	0.59	70.8			2.50
Thu-12	37.0				1.00	1.00	61.3			3.20
Fri-13	41.3				0.47	0.47	68.8			2.40
Sat-14	42.1				0.60	0.60	64.2			2.10
Sun-15	38.6				0.93	0.93	62.8			2.50
Mon-16	42.5				0.65	0.65	64.2			2.10
Tue-17	42.8				0.45	0.45	62.7			2.00
Wed-18	42.8				0.40	0.40	62.7			2.00
Thu-19	38.4				0.45	0.45	56.9			1.90
Fri-20	24.2				0.46	0.46	60.1			2.00
Sat-21	44.0				0.50	0.50	56.1			2.20
Sun-22	43.5				1.10	1.10	58.2			2.50
Mon-23	39.4				0.56	0.56	59.3			2.40
Tue-24	41.8				0.20	0.20	65.0			1.90
Wed-25	36.0				0.10	0.10	58.5			1.60
Thu-26	36.1				0.08	0.08	55.7			1.70
Fri-27	36.6				0.10	0.10	53.8			1.50
Sat-28	36.4				0.10	0.10	57.0			1.60
Sun-29	36.6				0.24	0.24	54.8			1.60
Mon-30	35.1				0.13	0.13	52.5			1.50
Average	38.7	37.7	---	---	0.53	0.53	60.1	48.0	---	2.16
Minimum	24.2	37.7	---	---	0.08	0.08	52.5	48.0	---	1.50
Maximum	44.0	37.7	---	---	1.50	1.50	70.8	48.0	---	3.20
GeoMean	---	---	---	---	---	---	---	---	---	---
TOTAL	---	---	---	---	---	---	---	---	---	---

DATE	NO_3+NO_2 (mg/L): RAW	NO_3+NO_2: OUTFALL 30	NO_3+NO_2: OUTFALL 20	NO_3+NO_2: OUTFALL 10: FEC	Chloride (mg/L): RAW	Chloride (mg/L): OUTFALL 30	Chloride (mg/L): OUTFALL 20	Chloride (mg/L): OUTFALL 10: FEC	*E. coli* (Counts/100 mL): RAW	*E. coli*: OUTFALL 30	*E. coli*: OUTFALL 20	*E. coli*: OUTFALL 10: FEC
Sun-01				13.2	70			81				4
Mon-02				12.6	73			74				4
Tue-03				12.8	81			80				9
Wed-04				13.8	80			83				9
Thu-05		0.67		11.5	78	91		85		2.1		5
Fri-06				10.5	71			83				3
Sat-07				11.1	87			83				6
Sun-08				11.7	95			99				4
Mon-09				12.1	104			99				2
Tue-10				10.7	275			136				5
Wed-11				9.36	124			234				9
Thu-12				10.6	106			144				7
Fri-13				9.64	106			116				4
Sat-14				10.7	103			111				4
Sun-15				11.7	82			104				4
Mon-16				11.4	90			92				6
Tue-17				11.7	98			94				5
Wed-18				12.3	110			102				8
Thu-19				11.8	120			117				8
Fri-20				12.5	124			125				4
Sat-21				12.0	112			133				3
Sun-22				12.1	97			126				2
Mon-23				13.2	121			103				9
Tue-24				11.9	112			108				10
Wed-25				12.0	160			123				4
Thu-26				10.6	138			169	2.1			5
Fri-27				10.1	152			147				10
Sat-28				9.69	106			152				2
Sun-29				9.41	87			111				6
Mon-30				10.8	96			95	2.8			10
Average	0.06	0.67	---	11.5	109	91	---	114	---	---	---	---
Minimum	< 0.01	0.67	---	9.36	70	91	---	74	2.1	2.1	---	2
Maximum	0.15	0.67	---	13.8	275	91	---	234	2.8	2.1	---	10
GeoMean	---	---	---	---	---	---	---	---	2.4	2.1	---	5
TOTAL	---	---	---	---	---	---	---	---	---	---	---	---

* Contact Laboratory for information about the quality assurance associated with the results

Enhanced Primary Treatment (EPT) Usage

Total Bypass (hr)	EPT Usage (hr)	% Usage	Total Bypass YTD (hr)	EPT Usage YTD (hr)	% Usage YTD
4	4	100%	826	826	100%

Report Comments

AEP Ref #

RAW	Untreated Influent into the plant
INF	Untreated wastewater from collection system
INFs	Influent, screened at the Headworks Diversion Structure
PE	Primary Effluent from conventional primaries
PE 30	Primary Effluent from conventional primaries discharged via Outfall 30
EPT	Enhanced Primary Treatment
EPE	Enhanced Primary Effluent
EPEPS	Enhanced Primary Effluent Pump Station
FE	Final Effluent from secondary treatment process (with biological nutrient removal). Pre-Ultraviolet disinfection.

FEC	Combined post-UV disinfection (FE+EPEPS)
OUTFALL 10	UV-disinfected, discharged via OUTFALL 10
OUTFALL 20	Combined Bypass (RAW + PE + EPE)
OUTFALL 30	Combined Bypass (INF + INFS + PE30 + EPE)
MPW	Membrane Product Water (Effluent re-use water)
ML	Megalitre (1,000,000 Litre)
MPN	Most Probable Number
NR	No Result
NS	No Sample
INS	Insufficient Sample
AEP	Alberta Environment & Parks

Alfredo Suarez
Senior Manager, Operations

Steve Craik
Director, Quality Assurance and Environment