

Old Bar Wastewater Treatment Plant
Plant Performance Report
August 2021

Digested Sludge Total Monthly Volume (ML) 66.5

Main data table with columns for Volume of Flow (ML) and Liquid Stream Quality. Includes rows for dates from Sun-01 to Tue-31 and summary rows for Average, Minimum, Maximum, and Total.

* Contact Laboratory for information about the quality assurance associated with the results

Enhanced Primary Treatment (EPT) Usage table with columns: Total Bypass (hr), EPT Usage (hr), % Usage, Total Bypass YTD (hr), EPT Usage YTD (hr), % Usage YTD

Report Comments
Variance to 24h raw composite sample noted for August 2 (30h) and August 3 (18h). Sample not lost, monitoring requirements still met

AEP Ref #

- RAW Untreated influent into the plant
INF Untreated wastewater from collection system
INFS Influent, screened at the Headworks Diversion Structure
PE Primary Effluent from conventional primaries
EPT Enhanced Primary Treatment
EPE Enhanced Primary Effluent
EPSPS Enhanced Primary Effluent Pump Station
FE Final Effluent from secondary treatment process (with biological nutrient removal), Pre-Ultraviolet disinfection

Alfredo Suarez M.Sc., P.Eng. Senior Manager, Operations
Jeff Charrois PHD Senior Manager, Analytical Operations & Process Development Teams