




**COMBINED WATER PRESSURE AND LEAKAGE TEST**  
FOR  
**EPCOR WATER SERVICES**

DEVELOPER: \_\_\_\_\_  
CONSULTANT: \_\_\_\_\_  
CONTRACTOR: \_\_\_\_\_  
LOCATION: \_\_\_\_\_

SUBDIVISION: \_\_\_\_\_  
DATE: \_\_\_\_\_  
PUMP LOCATION: \_\_\_\_\_

DIAGRAM OF TEST AREA



	Time	Read	Pressure "P" (kPa)
Start	14:00	140	1035 kPa
Finish	16:00	148	1035 kPa
Millimeters Drop			8mm
<b>Total Actual Leakage (litres)</b>			<b>2.19</b>

Length (m)	Size "D" (mm)	Type	Number of Joints "J"	Leakage Allowed "L <sub>M</sub> " (litres)
134	300	PVC	22 + 20 = 42	6.32
20	200	PVC	3 + 4 = 7	0.70
50	150	PVC	8 + 16 = 24	1.81
	50	Copper	0	0.00
2	150	Hydrant	8	0.60
<b>Total Allowable Leakage (litres)</b>				<b>9.43</b>

CONTRACTOR'S REPRESENTATIVE: \_\_\_\_\_  
CONSULTANT'S REPRESENTATIVE: \_\_\_\_\_

**TEST TO BE WITNESSED BY CONSULTANT'S REPRESENTATIVE WITH RESULTS  
CERTIFIED BY A PROFESSIONAL ENGINEER**