



20170215 08:45 cawright 2512-18.dgn

- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SPECIFIED.
 2. COMPACT GRAVEL BASE TO A MINIMUM 95% OF THE MAXIMUM DENSITY IN THE BOULEVARD.
 3. IF COVER ON COPPER PIPE IS 2.0m OR LESS, INSTALL INSULATION AS PER DWG 2511-08.
 4. FRAME AND COVER CANNOT FALL WITHIN WALK.

	TYPICAL 50mm MANUAL AIR VENT IN BOULEVARD WITH 1.5 m MONOLITHIC WALK			DRAWING NUMBER
	APPROVED MARCH 2017	DRAWN BY DV/CW	APPROVED	2512-18
SCALE N T S	CHECKED BY David M.	 DIRECTOR, WATER DISTRIBUTION AND TRANSMISSION		REVISION 0