



CROSS SECTION

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SPECIFIED.
2. NUMBER, SPACING, TYPE AND WEIGHT OF ANODES TO BE DETERMINED BY ENGINEER
3. NEW STEEL MAINS - INSTALLATION OF A THIRD ANODE TO BE SET IN TRENCH AT 45° TO EXCAVATION WALL WITH 3.0 M MINIMUM BETWEEN ANODES.
4. PLACE SAND AROUND PIPE IN 150 LIFTS AND COMPACT TO 95% STANDARD PROCTOR DENSITY.

20170215 10:49 cawright 2516-1.DGN

EPCOR

ANODE TEST STATION INSTALLATION

APPROVED
MARCH 2017

DRAWN BY
Dale Vandenberg

APPROVED

Shuan Qiu

DRAWING NUMBER

2516-01

SCALE
N T S

CHECKED BY
Doug S.

DIRECTOR, WATER DISTRIBUTION AND TRANSMISSION

REVISION 0