



**NOTES:**

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SPECIFIED.
2. MIN. DISTANCE FROM ANODE TO PIPE IS 150mm.
3. INSTALL ANODE AT APPROX. PIPE DEPTH IN NATIVE SOIL.
4. ALL ZINC ANODES ON FITTINGS AND VALVES ARE 2.3kg (5lb).
5. ALL ZINC ANODES ON HYDRANTS ARE 5.5kg (12lb).
6. ZINC ANODES TO BE EMBEDDED INTO TRENCH WALL TO PROVIDE FOR A MINIMUM OF 50mm OF NATIVE CLAY COMPLETELY SURROUNDING THE ANODE.
7. ANODES TO BE AT LEAST 300mm CLEAR OF THRUST BLOCK.

20170215 11:01 cawright 2516-3.DGN

	ANODE INSTALLATION AT HYDRANT AND CONNECTION TO EXISTING CAST IRON MAINS			DRAWING NUMBER
	APPROVED <b>MARCH 2017</b>	DRAWN BY <i>Dale Vandenberg</i>	APPROVED <i>Susan Ol</i>	2516-03
SCALE <b>N T S</b>	CHECKED BY <b>Doug S.</b>	DIRECTOR, WATER DISTRIBUTION AND TRANSMISSION	REVISION 0	