


NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SPECIFIED.
2. MINIMUM DISTANCE FROM ANODE TO PIPE, FITTING, VALVE OR HYDRANT IS 150mm.
3. INSTALL ANODE AT APPROX. PIPE DEPTH IN NATIVE SOIL.
4. ALL ZINC ANODES ON FITTINGS AND VALVES ARE 2.3kg (5lb).
5. ZINC ANODES TO BE EMBEDDED INTO TRENCH WALL TO PROVIDE FOR A MINIMUM OF 50mm OF NATIVE CLAY COMPLETELY SURROUNDING THE ANODE.
6. ANODES TO BE AT LEAST 300mm CLEAR OF THRUST BLOCK

20170215 11:03 cawright 2516-4.DGN

	TYPICAL ANODE INSTALLATION FOR IRON FITTINGS USED WITH PVC WATER MAINS			DRAWING NUMBER
	APPROVED MARCH 2017	DRAWN BY <i>Dale Vandenberg</i>	APPROVED <i>Awsan</i>	2516-04
SCALE N T S	CHECKED BY Doug S.	DIRECTOR, WATER DISTRIBUTION AND TRANSMISSION	REVISION 0	